

Compliance Status Report up to 30th Nov 2022 of Environmental Clearance for Pradhan Mantri Awas Yojana (PMAY) Housing Housing Scheme at Plot no. 3, Sector- 16, near Kharkopar Railway Station, Ulwe Node, Navi Mumbai, Taluka - Panvel, District-Raigad



Environment Compliance Report

SPECIFIC CONDITIONS

SPECIFIC CONDITIONS	
1	PP to submit & upload copy of LOI received for proposed project.
2	PP to submit Undertaking from CIDCO regarding nodal STP of CIDCO is sufficing for additional capacity of the project.
3	PP have provisional NOC, PP to submit the CFO NOC
4	PP to submit the sewerage network, water supply, storm water drain NOC from local planning authority
5	PP to submit clear design & permission of storm water drain approved by SWD department of local body
6	PP to incorporate biodiversity mitigation measures suggested in EIA should be incorporated in planning & implement the same.
7	PP to revise the wind analysis considering the stilt also
8	PP to provide more mitigation measures to reduce the heat island effect
9	Committee noted that, as sewer is directly connected to nodal STP, PP i.e., local planning authority (CIDCO) to recycle that sewerage & use treated wastewater for flushing, gardening etc. minimum to 65%
10	PP to provide mitigation measures to reduce noise pollution
11	The PP to get NOC from competent authority with reference to Thane creek flamingo sanctuary if the project site falls within 10 Km radius from the said sanctuary boundary. The planning authority to ensure fulfilment of this condition before granting CC
12	PP to ensure that CER plan gets approved from Municipal Commissioner.
13	PP Shall comply with Standard EC conditions mentioned in the Office Memorandum issued by MoEF& CC vide F.No.22-34/2018-1A.111 dt.04.01 .2019.
14	SEIAA decided to grant EC for FS1:179422.97 m2, Non- FS1:159728.98 m2 and Total BIJA: 339151.95 m2 (Plan Approval no-LOI no CIDCO/SR.Arch(BP-IHP)2019/354, dated- 08.08 2019)

All documents related to Special conditions already submitted by MOEF Consultant on portal



Environment Compliance Report

GENERAL CONDITIONS

Point 1:- E-waste shall be disposed through Authorized vendor as per E-waste (Management and Handling) Rules, 2016

Not Applicable

GENERAL CONDITIONS

Point 2:- The Occupancy Certificate shall be issued by the Local Planning Authority to the project only after ensuring sustained availability of drinking water, connectivity of sewer line to the project site and proper disposal of treated water as per environmental norms

As of now construction work in progress

GENERAL CONDITIONS

Point 3:- This environmental clearance is issued subject to obtaining NOC from Forestry & Wildlife angle including clearance from the standing committee of the National Board for Wildlife as if applicable & this environment clearance does not necessarily implies that Forestry & Wild life clearance granted to the project which will be considered separately on merit.

Not Applicable



Environment Compliance Report

GENERAL CONDITIONS

Point 4:- PP has to abide by the conditions stipulated by SEAC& SEIAA.

For Info.

Environment Compliance Report

GENERAL CONDITIONS

Point 5:- The height, Construction built up area of proposed construction shall be in accordance with the existing FSI/FAR norms of the urban local body & it should ensure the same along with survey number before approving layout plan & before according to commencement certificate to proposed work. Plan approving authority should also ensure the zoning permissibility for the proposed project as per the approved development plan of the area.

Architect
Hafeez
Contractor

Letter No: AHC_CIDCO_PKG-IV_511

Date: 19th May, 2022

To Whom It May Concern,

Subject: Proposed Mass Housing Scheme on Plot no 03, Sector 16A, Kharkopar (East), at Ulwe, Navi Mumbai for CIDCO LTD. (UNDER PMAY)

Proposal No. CIDCO/BP-IHP/2019/119

Ref. No. CIDCO/SR.ARCH.(BP-IHP)/2020/357-R1

Date: 13/05/2020

Sir,

Attached below is the details of Proposed Mass Housing Scheme on Plot no 03, Sector 16A, Kharkopar East, at Ulwe, Navi Mumbai for the Residential and Comm. Buildings. with reference to LOI letter no CIDCO/SR.ARCH.(BP-IHP)/2020/357-R1

Preamble of the said proposal is as given below:-

1.	Name of the Owner	Superintendent Engineer (A-P1 & HSG)		
2.	Name of the Developer	CIDCO Ltd.		
3.	Property Details	Plot no 03, Sector 16A, at Kharkopar (East), at Ulwe, Navi Mumbai.		
4.	Area Statement			
a.	Plot area	48167.81 Sq. Mt.		
b.	Permissible F.S.I.	2.3		
c.	Permissible BUA	102336.6 Sq. Mt.		
d.	Proposed BUA (F.S.I. Area)	80737.19 Sq. Mt.		
e.	BUA under Tree of F.S.I.	76932.49 Sq. Mt.		
f.	Total Construction Area	157639.69 Sq.Mt.		
5.	Number of Buildings	Type	Nos.	Floors Height
		EWS-A [R]	21 Bldgs.	Gr + 14 47.50 Mtrs.
6.	R.S. Area	7671.98 SQ.M. (16%)		
7.	Permissible Height of Buildings as per Height clearance:	35.10 Mtrs.		

HAFEEZ CONTRACTOR
A. I.I.A. G.D Arch. M.S Arch & U.D (USA)
Ph.D (Hon) Arch. Ph.D (Hon) Housing

Architect
Hafeez
Contractor

8.	No. Of trees to be Planted	1 tree / 100 Sq.mt of plot area (GDCR) – 482 No. 1 tree/ 80 Sq.mt of Plot area (MOEF) – 602 No. Proposed Tree Plantation – 1380 No.	
9.	Number and Area Of Basement.	N.A.	
10.	Number and Area Of Podium	N.A.	
11.	Right of way (width of the road from nearest fire Station)	24.0m Wide ROW	
12.	Width of all internal road	12m, 9.00m and 6m Wide driveway	
13.	Parking	Cars	Required Parking Spaces = 680 Nos. Proposed Parking Spaces = 693 Nos.
		Bikes	Required Parking Spaces = 68 Nos. Proposed Parking Spaces = 84 Nos.
14.	Tenements	Commercial - 36 Nos. Residential - 1332 Nos.	
15.	Community Centre Area	257.300 Sq. Mt.	

Thanking you,

Yours faithfully,



Mubashir Jabir
Associate



HAFEEZ CONTRACTOR
A. I.I.A. G.D Arch. M.S Arch & U.D (USA)
Ph.D (Hon) Arch. Ph.D (Hon) Housing

Environment Compliance Report

GENERAL CONDITIONS

Point 6:- If applicable Consent for Establishment" shall be obtained from Maharashtra Pollution Control Board under Air and Water Act and a copy shall be submitted to the Environment department before start of any construction work at the site

Attached Copy


MAHARASHTRA POLLUTION CONTROL BOARD				
Tel: 24010706/24010437 Fax: 24023516 Website: http://mpcb.gov.in Email: cac-cell@mpcb.gov.in			Kalpataru Point, 2nd and 4th floor, Opp. Cine Planet Cinema, Near Sion Circle, Sion (E), Mumbai-400022	
No:- Format1.0/CAC-CELL/UAN No.0000093638/CE - 2011000786		Date: 12/11/2020		
To, City Industrial Development Corporation of Maharashtra Ltd (CIDCO), Pradhan Mantri Awas Yojana (PMAY) Housing Scheme, At. Plot No. 3, Sector-16A, Near Kharkopar Railway Station (East), Ulwe Node, Navi Mumbai, Tal. Panvel, Dist. Raigad.				
Sub: Consent to Establish for proposed Residential/Commercial Construction project under Pradhan Mantri Awas Yojana (PMAY) Housing Scheme under L.S.I Red Category				
Ref: 1. Minutes of Consent Appraisal Committee meeting held on 18/09/2020.				
Your application NO. MPCB-CONSENT-0000093638				
For: Grant of Consent to Establish under Section 23 of the Water (Prevention & Control of Pollution) Act, 1974 & under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization / Renewal of Authorization under Rule 6 of the Hazardous & Other Wastes (Management & Transboundry Movement) Rules 2016 is considered and the consent is hereby granted subject to the following terms and conditions and as detailed in the schedule I,II,III & IV annexed to this order:				
<ol style="list-style-type: none"> The Consent to Establish is granted for a period upto commissioning of project The capital investment of the project is Rs.382.83 Crs. (As per undertaking submitted by pp). The Consent to Establish is valid for Residential/Commercial Construction project under Pradhan Mantri Awas Yojana (PMAY) Housing Scheme named as City Industrial Development Corporation of Maharashtra Ltd (CIDCO), Pradhan Mantri Awas Yojana (PMAY) Housing Scheme, At. Plot No. 3, Sector-16A, Near Kharkopar Railway Station (East), Ulwe Node, Navi Mumbai, Tal. Panvel, Dist. Raigad. on Total Plot Area of 48,167.81 SqMtrs for construction BUA of 1,57,689.68 SqMtrs including utilities and services. Conditions under Water (P&CP), 1974 Act for discharge of effluent: 				
Sr No	Description	Permitted (in CMD)	Standards to	Disposal
1.	Trade effluent	Nil	Nil	Nil
2.	Domestic effluent	680	As per Schedule - I	The treated effluent shall be 60% recycled for secondary purposes such as toilet flushing, air conditioning, cooling tower make up, firefighting etc. and remaining shall be connected to the sewerage system provided by local body
				
M/s. City and Industrial Development Corporation of Maharashtra Limited (CIDCO) (PMAY)CE/UAN No.MPCB-CONSENT-0000093638				

Environment Compliance Report

GENERAL CONDITIONS

Point 7:- All required sanitary and hygienic measures should be in place before starting construction activities and to be maintained throughout the construction phase

Attached Photos



Environment Compliance Report

GENERAL CONDITIONS

Point 8:-Adequate drinking water and sanitary facilities should be provided for construction workers at the site. Provision should be made for mobile toilets. The safe disposal of wastewater and solid wastes generated during the construction phase should be ensured

Attached Photos



Environment Compliance Report

GENERAL CONDITIONS

Point 9:-The solid waste generated should be properly collected and segregated. DIY/inert solid waste should be disposed of to the approved sites for land filling after recovering recyclable material

Attached Photos



Environment Compliance Report

GENERAL CONDITIONS

Point 10:- Disposal of muck during construction phase should not create any adverse effect on the neighboring communities and be disposed taking the necessary precautions for general safety and health aspects of people, only in approved sites with the approval of competent authority


All excavated soil has been stocked at site premises only.



GENERAL CONDITIONS

Point 11:- Arrangement shall be made that wastewater and storm water do not get mixed


Toilets are isolated in location away from project.



GENERAL CONDITIONS

Point 12:- All the topsoil excavated during construction activities should be stored for use in horticulture/
Landscape development within the project site


Attached Photos



GENERAL CONDITIONS

Point 13:- Additional soil for leveling of the proposed site shall be generated within the sites (to the extent possible) so that natural drainage system of the area is protected and improved.

Levelled soil photo attached





Environment Compliance Report

GENERAL CONDITIONS

Point 14:- Green Belt Development shall be carried out considering CPCB guidelines including selection of plant species and in consultation with the local DFO/ Agriculture Dept

Landscape drawing development in progress

Environment Compliance Report

GENERAL CONDITIONS

Point 15:- Soil and ground water samples will be tested to ascertain that there is no threat to ground water quality by leaching of heavy metals and other toxic contaminants expenditure should reported to the MPCB & this department.

Attached Report



BUREAU VERITAS

Page 1 of 1



NABL Accredited Lab

Test order / Report No. D91PI / WATER - 25941C/06/1/D/2021_1
Date of Receipt - 02-01-2021
TEST REPORT

Date : 11-01-2021
ULR-TC549121090950281F

LARSEN & TOUBRO LIMITED,
Land 3 Business Towers, 5th floor, Wing B, Sakinaka Road, Powai,
Mumbai-400072

CHEMICAL TESTING

TEST REPORT ON ANALYSIS OF WATER

Source of sample : Sample supplied by the Customer.
No of Samples Tested : 01 (One only)
L/N : 21000099
Identification # : Ground Water
Customer's Reference : L&T/BS&R/BS&R/CIDCO/QUALITY/06P/014, dt.31.12.2020
Project # : CIDCO Project
Sample ID # : Plot2 / T3
Lab Reference No. : 2021/am/2100043
Condition of Sample : Satisfactory
Period of Test : 04-01-2021 to 07-01-2021
Test Method : IS: 456-2000 and IS: 3025 (Part 11, 15, 17, 18, 22, 23, 24, 32)-1983

Sl.No	Particulars	Results	Stipulations of IS:456-2000 (Reaffirmed 2011) (water for construction purpose)
1	Quantity of 0.02N NaOH required to neutralise 100ml of water sample using phenolphthalein as an indicator	1.00 ml ✓	Shall not be more than 5 ml
2	Quantity of 0.02N H ₂ SO ₄ required to neutralise 100ml of water sample using mixed indicator	24.60 ml ✓	Shall not be more than 25ml
3	Chlorides as Cl ⁻	732.66 mg/l ✓	500 mg/l max. for RCC 1000 mg/l max. for RCC
4	Sulphates as SO ₄	142.08 mg/l ✓	400 mg/l max.
5	Inorganic Solids	1,074.00 mg/l ✓	3000 mg/l max.
6	Suspended matter	21.00 mg/l ✓	2000 mg/l max.
7	Organic Solids	678.00 mg/l ✓	200 mg/l max.
8	pH Value	7.72 ✓	Shall not be less than 6

As furnished by the customer

Note : 1. The Results relate only to the samples tested
2. Report shall not be reproduced, except in full, without the written approval of the lab.
3. Any correction shall make this report.

for **BUREAU VERITAS (INDIA) PRIVATE LIMITED**
Construction Services Laboratory
Dinesh Gaikwad


Lab Manager-Chemical
Authorised Signatory

*Ground Water @ Plot2/T3
Sample
For Rec OK
for Rec NOT OK
RD
Rishabh
L&T @ Rec*

Bureau Veritas (India) Pvt. Ltd. - Construction Services Laboratory
Plot No. BM/84, TTC Ind. Area, Off Thane Belpare Road, M.I.D.C., Digha, Navi Mumbai - 401 206, INDIA
Tel: +91 22 59948370 • sales.mumbai@bureauveritas.com/admlab.mumbai@bureauveritas.com • www.bureauveritas.com
CIN: U74904MH2011PTC194762
http://103.57.125.31/bvapi/print_water.php?report_type=multiple&job_id=406249&t_i... 11-Jan-21



Environment Compliance Report

GENERAL CONDITIONS

Point 16:- Construction spoils, including bituminous material and other hazardous materials must not be allowed to contaminate watercourses and the dumpsites for such material must be secured so that they should not leach into the ground water

Not Applicable



Environment Compliance Report

GENERAL CONDITIONS

Point 17:- Any hazardous waste generated during construction phase should be disposed of as per applicable rules and norms with necessary approvals of the Maharashtra Pollution Control Board

Not Applicable

Environment Compliance Report

GENERAL CONDITIONS

Point 18:- The diesel generator sets to be used during construction phase should be low Sulphur diesel type and should conform to Environments (Protection) Rules prescribed for air and noise emission standards

Not used at site , Power is 100 % on MSEDCL attached Photos



Environment Compliance Report

GENERAL CONDITIONS

Point 19:- The diesel required for operating DG sets shall be stored in underground tanks and if required, clearance from concern authority shall be taken

Not used at site , Power is 100 % on MSEDCCL



Environment Compliance Report

GENERAL CONDITIONS

Point 20:- Vehicles hired for bringing construction material to the site should be in good condition and should have a pollution check certificate and should conform to applicable air and noise emission standards and should be operated only during non-peak hours.

Form 59
(See rules 115 (2))

Pollution Under Control Certificate
Authorised By :
Government of Maharashtra

Date : 26/08/2022
Time : 11:56:27 AM
Validity upto : 25/02/2023

Certificate SL No. : MH04301140004951
Registration No. : MH10DL5169
Date of Registration : 12/Nov/2020
Month & Year of Manufacturing : August 2018
Valid Mobile Number : ****3264
Emission Norms : Bharat (Trem) Stage III A
Fuel : DIESEL
F Code : MH0430114
GSTIN :
Fees : Rs.150.00
(GST to be paid extra as applicable)
ML observation : No

Vehicle Photo with Registration plate
60 mm x 30 mm

Sr. No.	Pollutant (as applicable)	Units (as applicable)	Emission limits	Measured Value (upto 2 decimal places)
1	Carbon Monoxide (CO)	percentage (%)	2500 ± 200	0.21
	Hydrocarbon, (THC/HC)	ppm		
High idling emissions	CO	percentage (%)	2500 ± 200	-
	RPM	RPM		
Smoke Density	Lambda	-	1 ± 0.03	2.45
	Light absorption coefficient	1/metre	2.45	

This PUC certificate is system generated through the national register of motor vehicles and does not require any signature.

Note : 1. Vehicle owners to link their mobile numbers to registered vehicle by logging to <https://vahan.parivahan.gov.in>

Authorised Signature with stamp of PUC operator
60mm x 20 mm

Form 59
(See rules 115 (2))

Pollution Under Control Certificate
Authorised By :
Government of Maharashtra

Date : 16/10/2022
Time : 10:31:28 AM
Validity upto : 15/04/2023

Certificate SL No. : MH01402200001170
Registration No. : MH10T1002
Date of Registration : 05/Nov/2012
Month & Year of Manufacturing : August 2012
Valid Mobile Number : ****7070
Emission Norms : BHARAT STAGE III
Fuel : DIESEL
F Code : MH0140220
GSTIN :
Fees : Rs.150.00(GST to be paid extra as applicable)
ML observation : No

Vehicle Photo with Registration plate
60 mm x 30 mm

Sr. No.	Pollutant (as applicable)	Units (as applicable)	Emission limits	Measured Value (upto 2 decimal places)
1	Carbon Monoxide (CO)	percentage (%)	2500 ± 200	-
	Hydrocarbon, (THC/HC)	ppm		
High idling emissions	CO	percentage (%)	2500 ± 200	-
	RPM	RPM		
Smoke Density	Lambda	-	1 ± 0.03	1.04
	Light absorption coefficient	1/metre	2.45	

This PUC certificate is system generated through the national register of motor vehicles and does not require any signature.


Note : 1. Vehicle owners to link their mobile numbers to registered vehicle by logging to <https://vahan.parivahan.gov.in>

Authorised Signature with stamp of PUC operator
60mm x 20 mm


Environment Compliance Report

GENERAL CONDITIONS

Point 21:- Ambient noise levels should conform to residential standards both during day and night. Incremental pollution loads on the ambient air and noise quality should be closely monitored during construction phase. Adequate measures should be made to reduce ambient air and noise level during construction phase, so as to conform to the stipulated standards by CPCB/MPCB



ADITYA ENVIRONMENTAL SERVICES PVT. LTD.
Testing Laboratory is certified by ISO 9001:2015& ISO 45001:2018
Recognized by MoEFCC as "Environmental Laboratory" valid up to 24.04.2024
Laboratory: P-1, MIDC, Mohopada, P.O. Rasayam, Dist. Raigad Pin 410222
Tel:-9112644844, CIN: U74999MH2001PTC132091



TC-7085

Quality Test Report

Ref. No.: AESPL/LAB/C/A-22/11/78 Issue Date: 28/11/2022


Name of Client	M/s. L&T Construction. CIDCO Housing Project - Kharkopar, Navi Mumbai			
Name of site	CIDCO HOUSING PROJECT, Kharkopar Navi Mumbai			
Nature of sample	Ambient Air			
Location of sample	Main Gate			
Sample Identification number	A- 22/11/78			
Sample Quantity	SO ₂ :1Bottle x 30 ml; NO _x :1Bottle x 30 ml; PM ₁₀₋₁ : Bladder:1			
Date, Start Time & period of sampling	21/11/2022	10:00 hrs	8 hrs	
Environmental Condition	Climate: Clear; Ambient Temp.:31°C			
Sample Monitored & Transported by	AESPL			
Date of sample receipt	22/11/2022			
Date of sample analysis	22/11/2022 to 27/11/2022			
Sampling equipment & Calibration status	RDS-1-06- calibration on 01/01/2022 due on 31/12/2022			
Project/ Job number	EK337WOD1000178 dtd 14 Mar 2021			
Reference of sampling	AESPL/LAB/QR/7.3.3/R-02			
Method of sampling & preservation	AESPL/LAB/SOP/7.3.1/A-01			

Sr. No.	Parameter	Result	Limits #	Unit	Method of analysis
1.	SO ₂	25.8	80	µg/m ³	IS 5182 (Part 2) RA2017
2.	NO ₂	30.2	80	µg/m ³	IS 5182 (Part 6) RA2017
3.	PM ₁₀	71.3	100	µg/m ³	IS 5182 (Part 23) RA2017
4.	CO	0.73	04 *	mg/m ³	IS 5182 (part 10) RA2019

[#] Specified under National Ambient Air Quality Standards by CPCB;
[*] 24 hourly monitoring values; [**] 1 hourly monitoring values.
Conformity Statement: The monitoring undertaken indicates that Ambient Air Quality Values for monitored parameters are within the levels stipulated under National Ambient Air Quality Standards (NAAQS)2009.

Note:

- The test report shall not be reproduced except in full, without written approval of laboratory.
- Results relate only to the items tested.
- Any query related to this report will be entertained within 15 days of the report issue date only.
- Decision Rule is applied.



Himani P. Joshi
(Authorized Signatory - Pollution & Environment)
-End of Test Report-

GENERAL CONDITIONS

Point 22:- Fly ash should be used as building material in the construction as per the provisions of Fly Ash Notification of September 1999 and amended as on 27th August 2003. (The above condition is applicable only if the project site is located within the 100Km of Thermal Power Stations). XX111. Ready mixed concrete must be used in building construction.

Not Applicable

Environment Compliance Report

GENERAL CONDITIONS

Point 23:- Ready mixed concrete must be used in building construction.

Attached Photos





Environment Compliance Report

GENERAL CONDITIONS

Point 24:- Storm water control and its re-use as per CGWB and BIS standards for various applications

Not Applicable

GENERAL CONDITIONS

Point 25:- Water demand during construction should be reduced by use of pre-mixed concrete, curing agents and other best practices referred.

Using Coaltar as curing compound as well as Waterproofing agent. Attached Photos



Environment Compliance Report

GENERAL CONDITIONS

Point 26:-The ground water level and its quality should be monitored regularly in consultation with Ground Water Authority

Attached Report



BUREAU VERITAS

Page 1 of 1



NABL Accredited Lab

Test order / Report No. D9191 / WATER - 25941C/06/12/2021_1
Date of Receipt - 02-01-2021

TEST REPORT

Date : 11-01-2021
ULR-TC54912109050281F

CHEMICAL TESTING

LARSEN & TOUBRO LIMITED,
Land 3 Business Towers, 5th Floor, Wing K, Sakinaka Road, Powai,
Mumbai-400072

TEST REPORT ON ANALYSIS OF WATER

Source of sample : Sample supplied by the Customer.
No of Samples Tested : 01 (One only)
L/N : 21000059
Identification # : Ground Water
Customer's Reference : L&T/BS&R/BS&R/CIDCO/QUALITY/06P/014, dt.31.12.2020
Project # : CIDCO Project
Sample ID # : Plot2 / T3
Lab Reference No. : 2021/am/2100043
Condition of Sample : Satisfactory
Period of Test : 04-01-2021 to 07-01-2021
Test Method : IS: 456-2000 and IS: 3025 (Part 11, 15, 17, 18, 22, 23, 24, 32)-1983

Sl.No	Particulars	Results	Stipulations of IS:456-2000 (Reaffirmed 2011) (water for construction purpose)
1	Quantity of 0.02N NaOH required to neutralise 100ml of water-sample using phenolphthalein as an indicator	1.00 ml ✓	Shall not be more than 5 ml
2	Quantity of 0.02N H ₂ SO ₄ required to neutralise 100ml of water sample using mixed indicator	24.60 ml ✓	Shall not be more than 25ml
3	Chlorides as Cl ⁻	732.66 mg/l ✓	500 mg/l max. for RCC. 1000 mg/l max. for RCC
4	Sulphates as SO ₄	142.08 mg/l ✓	400 mg/l max.
5	Inorganic Solids	1,074.00 mg/l ✓	3000 mg/l max.
6	Suspended matter	21.00 mg/l ✓	2000 mg/l max.
7	Organic Solids	678.00 mg/l ✓	200 mg/l max.
8	pH Value	7.72 ✓	Shall not be less than 6

As furnished by the customer

Note : 1. The Results relate only to the samples tested
2. Report shall not be reproduced, except in full, without the written approval of the lab.
3. Any correction shall state the report.

for **BUREAU VERITAS (INDIA) PRIVATE LIMITED**
Construction Services Laboratory
Dinesh Gaikwad




Lab Charge-Chemical
Authorised Signatory

Ground Water @ Plot2/T3
Sample OK
For Rec. NOT OK
for Rec. NOT OK
S.D. Robinson
L&T Office

Bureau Veritas (India) Pvt. Ltd. - Construction Services Laboratory
Plot No. BM/84, TTC Ind. Area, Off Thane Belpare Road, M.I.D.C., Digha, Navi Mumbai - 401 206, INDIA
Tel: +91 22 59948370 • sales.mumbai@in.bureauveritas.com/adminlab.mumbai@in.bureauveritas.com • www.bureauveritas.com/in
CIN: U74904MH1992D111C194762
http://103.57.125.31/bvnp/print_water.php?report_type=multiple&job_id=406249&t_i... 11-Jan-21

Environment Compliance Report

GENERAL CONDITIONS

Point 27:- The installation of the Sewage Treatment Plant (STP) should be certified by an independent expert and a report in this regard should be submitted to the MPCB and Environment department before the project is commissioned for operation. Discharge of this unused treated effluent if any should be discharge in the sewer line. Treated effluent emanating from STP shall be recycled/ reused to the maximum extent possible. Discharge of this unused treated effluent if any should be discharge in the sewer line. Treatment of 100% grey water by decentralized treatment should be done. Necessary measures should be made to mitigate the odour problem from STP

Attached Photos





Test Report

Test Order / Report No.: BVPL/ WATER/25941C/11205/2021 Date: 08.06.2021
 Date of Receipt: 28.05.2021 Page 1 of 1

LARSEN & TOUBRO LIMITED.
 1 and 7 Business Towers, 10th Floor, Wing-B,
 Sakinaka Road, Powai, Mumbai-400072

Source of sample : Sample supplied by the customer
 Number of samples Tested : 01 (One only)
 Customer's Reference : LR/066/PURAB/CIDCO/QUALITY/033, Dt: 26.05.2021
 Condition of sample : Satisfactory
 Lab Reference Number : 2021/May/112080
 Sample Details #: Waste water sample from STP Filtration Tank
 Project #: Khatrapati Site
 Period of Test : 17.05.2021 to 05.06.2021

Sl. No.	Test Conducted	Results	Units	MPCB Limits	Methods
1	Chemical Oxygen Demand	148.09	mg/ltr	Max 250.0	IS-3025(Part-5):1993
2	Biochemical Oxygen Demand @27°C, 3 Days	7.40	mg/ltr	Max 100.0	IS-3025(Part-4):2006
3	Total Suspended Solids	145.0	mg/ltr	Max 100.0	IS-3025(Part-1):1984

As furnished by the customer.

Notes: 1. The Results relate only to the samples tested.
 2. Report shall not be reproduced, except in full, without the written approval of the lab.
 3. Any correction invalidates this report.

For Bureau Veritas (India) Pvt. Ltd.
 Construction Services Laboratory

Dinesh Galkwad
 Lab In-Charge-Chemical
 Authorised Signatory

OHM/W3937

Bureau Veritas (India) Pvt. Ltd. - Construction Services Laboratory
 Plot No. 65/94, T.T.C. Ind. Area, Off. Hume, Balapur Road, MIDC, Digha, Navi Mumbai - 401 708, INDIA
 Tel. +91 22 50991870 • sales@bvt.in • bvt@bvt.com • info@bvt.com • www.bvt.com



Environment Compliance Report

GENERAL CONDITIONS

Point 28:- Permissions to draw ground water and construction of basement if any shall be obtained from the competent Authority prior to construction/operation of the project

No Water is drawn from ground

Environment Compliance Report

GENERAL CONDITIONS

Point 29:- Separation of grey and black water should be done by the use of dual plumbing line for separation of grey and black water

Attached Drawing





Environment Compliance Report

GENERAL CONDITIONS

Point 30:- Fixtures for showers, toilet flushing, and drinking should be of low flow either by use of aerators or pressure reducing devices or sensor-based control.

Material Selection in process



Environment Compliance Report

GENERAL CONDITIONS


Point 31:- Use of glass may be reduced up to 40% to reduce the electricity consumption and load on air conditioning. If necessary, use high quality double glass with special reflective coating in windows.

Will be implemented in the proposed Commercial building once façade is finalized.
For Residential buildings not applicable.

GENERAL CONDITIONS

Point 32:- Roof should meet prescriptive requirement as per Energy Conservation Building Code by using appropriate thermal insulation material to fulfil requirement.

Attached drawings.



GENERAL CONDITIONS

Point 33:- Energy conservation measures like installation of CFLs /TFLs for the lighting the areas outside the building should be integral part of the project design and should be in place before project commissioning. Use CFLs and TFLs should be properly collected and disposed of /sent for recycling as per the prevailing guidelines/rules of the regulatory authority to avoid mercury contamination. Use of solar panels may be done to the extent possible like installing solar streetlights, common solar water heaters system. Project proponent should install, after checking feasibility, solar plus hybrid non-conventional energy source as source of energy.

Attached Photos of LED lights



GENERAL CONDITIONS

Point 34:- Diesel power generating sets proposed as source of backup power for elevators and common area illumination during operation phase should be of enclosed type and conform to rules made under the Environment (Protection) Act, 1986. The height of stack of DG sets should be equal to the height needed for the combined capacity of all proposed DG sets. Use low Sulphur diesel. The location of the DG sets may be decided with in consultation with Maharashtra Pollution Control Board.


Material Selection in process

Environment Compliance Report


GENERAL CONDITIONS

Point 35:- Noise should be controlled to ensure that it does not exceed the prescribed standards. During night-time the noise levels measured at the boundary of the building shall be restricted to the permissible levels to comply with the prevalent regulations.

Attached Report



ADITYA ENVIRONMENTAL SERVICES PVT. LTD.
Testing Laboratory is certified by ISO 9001:2015&ISO 45001:2018
Recognized by MoEFCC as "Environmental Laboratory" valid up to 24.04.2024
Laboratory: P-1, MIDC, Mulund, P.O. Sasaram, Dist. Raigad Pin 410222
Tel: 9112844844, CN: U74999MH2001PTC132091



TC.7085

Quality Test Report

Ref: AESPL/LAB/C/N-22/11/87 Issue Date: 23/11/2022


Name of the client	M/s. L&T Construction.	
Name of site	CIDCO Housing Project - Kharkopar, Navi Mumbai	
Monitoring details	: Ambient Noise	
Location details	: At the periphery of site.	
Sample Identification No	: N-22/11/87	
Date of sampling	: 21/11/2022	
Period of sampling	: Daytime	
Environmental condition	: Climate: Clear; Ambient Temp: 31°C	
Monitored & transported by	: AESPL	
Date of data receipt	: 22/11/2022	
Sampling equipment	: Noise meter - Centre SL-1-02	
Calibration status	: Calibration details: 02/11/2022 to 01/11/2023	
Project/ Job number	: L&T/22/11/001/1/8 and 14 Mar 2021	
Reference of sampling	: AESPL/LAB/OR/7.3.3/R-02	
Method of sampling	: IS 9589 EA-2014	

Sr. No.	Location	Noise Level Day time dB(A) Leq
1.	Gate-1, plot no 2- Main gate	64.9
2.	Plot-2 EA-03	64.7
3.	Plot-2 EA-02	64.8
4.	Plot-2 Decarabon area	64.3
5.	Plot-3 Gate no. 4 main gate	64.2
6.	Plot-3 Gate no. 2 main gate	64.5
7.	Plot-3 Cluster-3	59.8
8.	Plot-3 Cluster-4	60.1
9.	Plot-3 Gate no 3	58.9
10.	Plot-3 Cluster-5	61.8
11.	Plot-3 Cluster-2	63.7
12.	Main office area	58.8
13.	UGT-01, plot-3	61.2
Limit as per EP Act for daytime at Commercial area		65

Conformity Statement: Noise Levels at all the locations are found to be below the stipulated limits

Note:

- The test report shall not be reproduced except in full, without written approval of laboratory
- Results relate only to the items tested
- Any query related to this report will be entertained within 15 days of the report issue date only.
- Decision rule is applied.



Himani P. Joshi.
(Authorized Signatory - Pollution & Environment)

~End of Test Report~

We Are Listening & Want to Improve - Complaint Register is Available with us Page 1 of 1

Reg. Office: 107, Hiranagar Industrial Estate, Mogal Lane, Malin, Mumbai - 400016 Tel: 022-42117500 E-mail: complaint@amsl.co.in

Environment Compliance Report

GENERAL CONDITIONS

Point 36:- Traffic congestion near the entry and exit points from the roads adjoining the proposed project site must be avoided. Parking should be fully internalized, and no public space should be utilized.

Planned accordingly.

Gate Entry ○



Environment Compliance Report

GENERAL CONDITIONS

Point 38:- The building should have adequate distance between them to allow movement of fresh air and passage of natural light, air and ventilation

ENVIRONMENTAL MANAGEMENT PLAN LIDPA TECH																				
No	Environmental Aspects	Standards	Impacts/Findings of studies	Design Considerations/ Mitigation Measures																
DESIGN SPECIFIC																				
1.	Shadow Analysis: The aim of the study is to assess the potential impact of the development on the neighboring properties which falls under key sunlight sensitive areas.	Not more than 50% of surface area of any building should be shaded for more than 40% time as per BRE standards.	Shadow analysis result shows that the most affected building is Community Centre with an average impact time of 03:42 hrs. The impact is 37% which is lesser than 40% as per BRE standards.	No mitigation measures required.																
No	Environmental Aspects	Standards	Impacts/Findings of studies	Design Considerations/ Mitigation Measures																
DESIGN SPECIFIC																				
2	Wind & Ventilation Analysis: Wind Analysis is done for external environment around the buildings to ensure that all the habitable areas are meeting the required ventilation rates.	Ventilation Requirement as per NBC 2016 has specified minimum ACPH required for various habitable spaces which are as follows: <table border="1" style="margin: 5px auto;"> <thead> <tr> <th>Space</th> <th>Required ACH (NBC 2016)</th> </tr> </thead> <tbody> <tr> <td>Living room</td> <td>3 - 6</td> </tr> <tr> <td>Bedroom</td> <td>2 - 4</td> </tr> <tr> <td>Kitchen</td> <td>4.5</td> </tr> </tbody> </table>	Space	Required ACH (NBC 2016)	Living room	3 - 6	Bedroom	2 - 4	Kitchen	4.5	Wind speed observed at various heights is between 1.10 m/s to 2.50 m/s. Ventilation rates achieved for various spaces are as follows: <table border="1" style="margin: 5px auto;"> <thead> <tr> <th>Space</th> <th>Achieved ACH</th> </tr> </thead> <tbody> <tr> <td>Living room</td> <td>>8</td> </tr> <tr> <td>Bedroom</td> <td>>6</td> </tr> <tr> <td>Kitchen</td> <td>>8</td> </tr> </tbody> </table>	Space	Achieved ACH	Living room	>8	Bedroom	>6	Kitchen	>8	No mitigation measures required.
Space	Required ACH (NBC 2016)																			
Living room	3 - 6																			
Bedroom	2 - 4																			
Kitchen	4.5																			
Space	Achieved ACH																			
Living room	>8																			
Bedroom	>6																			
Kitchen	>8																			

Environment Compliance Report

GENERAL CONDITIONS

Point 38:- The building should have adequate distance between them to allow movement of fresh air and passage of natural light, air and ventilation

ENVIRONMENTAL MANAGEMENT PLAN																					
No.	Environmental Aspects	Standards	Design Considerations/ Mitigation Measures	Results	Mitigation Measures																
DESIGN SPECIFIC																					
3.	Daylight Analysis: For the daylight simulation, typical flats/units in all the directions at different levels (Lower, Middle and Upper Floors) have been considered. It is to be noted that the DL level achieved in these flats/units are the average weighted lux levels.	Daylight levels available should meet the minimum lighting levels mentioned in SP 41 which are as follows: <table border="1" data-bbox="619 982 882 1201"> <thead> <tr> <th>Space</th> <th>Required lux levels (SP 41)</th> </tr> </thead> <tbody> <tr> <td>Living room</td> <td>50</td> </tr> <tr> <td>Bedroom</td> <td>152</td> </tr> <tr> <td>Kitchen</td> <td>200</td> </tr> </tbody> </table>	Space	Required lux levels (SP 41)	Living room	50	Bedroom	152	Kitchen	200	Design recommendations are as follows: <ul style="list-style-type: none"> • Light colored exterior surfaces of Proposed Buildings. • Light coloured wall, ceilings and floor finishes. • Light coloured grid pavers / tiles / roads for hardscaping around the Proposed Buildings. • Window Glass with visual light transmission of 45% in Proposed Buildings. 	After consideration of the recommendations the project is achieving an average weighted lux levels of more than 200 lux in all habitable spaces which is higher than the requirement <table border="1" data-bbox="1218 1079 1512 1242"> <thead> <tr> <th>Space</th> <th>Achieved lux levels</th> </tr> </thead> <tbody> <tr> <td>Living</td> <td>215</td> </tr> <tr> <td>Bedroom</td> <td>235</td> </tr> <tr> <td>Kitchen</td> <td>225</td> </tr> </tbody> </table>	Space	Achieved lux levels	Living	215	Bedroom	235	Kitchen	225	No Mitigation Measures required.
Space	Required lux levels (SP 41)																				
Living room	50																				
Bedroom	152																				
Kitchen	200																				
Space	Achieved lux levels																				
Living	215																				
Bedroom	235																				
Kitchen	225																				

GENERAL CONDITIONS

Point 38:- The building should have adequate distance between them to allow movement of fresh air and passage of natural light, air and ventilation



ENVIRONMENTAL MANAGEMENT PLAN

ULTRA TECH


No	Environmental Aspects	Standards	Impacts / Findings of studies	Design Considerations/ Mitigation Measures
DESIGN SPECIFIC				
4.	Heat Island Effect Analysis: An urban heat island is a climatic phenomenon in which urban areas have higher air temperature than their rural surroundings as a result of anthropogenic modifications of land surfaces, significant energy use and its consequent generation of waste heat.	There are no standards as such to measure the Heat Island Effect impact. But the comparison between Base Case & Proposed Case can be analyzed in terms of incident Solar Radiation & change in ambient air temperature.	Ambient air temperature may increase from 27.46 °C to 27.50°C i.e., an increase of 0.04°C in temperature due to Proposed Project.	Though ambient temp will increase the solar insolation will decrease, there is reduction in solar insolation on site due to the following proposed measures <ul style="list-style-type: none"> • Mutual shading • Landscape • Solar Panels • China Mosaic Tiles • Shaded Parking • Light coloured Grid pavers • High albedo roads • Light coloured facade There is reduction in solar insolation from 4,794 to 3,931 Wh/sq.m. i.e., a reduction of 19.6% with the help of proposed mitigation measures.

Environment Compliance Report


GENERAL CONDITIONS

Point 39:- Regular supervision of the above and other measures for monitoring should be in place all through the construction phase, to avoid disturbance to the surroundings.

Attached report



ADITYA ENVIRONMENTAL SERVICES PVT. LTD.
Testing Laboratory is certified by ISO 9001:2015& ISO 45001:2018
Recognized by MoEFCC as "Environmental Laboratory" valid up to 24.04.2024
Laboratory: P-1, MIDC Molepada, P.O. Raxayani, Dist. Raigad Pin 410222
Tel: 9112844844, QIN: 074999MH2001PTC32091



TC 2085

Quality Test Report

Ref. No.: AESPL/LAB/C/A-22/11/79 Issue Date: 28/11/2022

Name of Client	: M/s. L&T Construction, CIDCO Housing Project - Kharkopar, Navi Mumbai				
Name of site	: CIDCO HOUSING PROJECT, Kharkopar Navi Mumbai				
Nature of sample	: Ambient Air				
Location of sample	: Plot No.3, Gate No.4				
Sample Identification number	: A-22/11/79				
Sample Quantity	: SO ₂ : 1Bottle x 30 ml; NOx: 1Bottle x 30 ml; PM ₁₀ -1: Bladder.1				
Date, Start Time & period of sampling	: 21/11/2022 09:45 hrs 8 hrs				
Environmental Condition	: Climate: Clear, Ambient Temp.: 31°C				
Sample Monitored & Transported by	: AESPL				
Date of sample receipt	: 22/11/2022				
Date of sample analysis	: 22/11/2022 to 27/11/2022				
Sampling equipment & Calibration status	: RDS-1-05- calibration on 01/01/2022 due on 31/12/2022				
Project/ Job number	: EK337WOD1000178 dtd 14 Mar 2021				
Reference of sampling	: AESPL/LAB/QR/7.3.3/R-02				
Method of sampling & preservation	: AESPL/LAB/SOP/7.3.1/A-01				


Sr. No.	Parameter	Result	Limits #	Unit	Method of analysis
1.	SO ₂	23.1	80	µg/m ³	IS 5182 (Part 2) RA2017
2.	NO _x	28.8	80	µg/m ³	IS 5182 (Part 6) RA2017
3.	PM ₁₀	69.5	100	µg/m ³	IS 5182 (Part 23) RA2017
4.	CO	0.75	04*	mg/m ³	IS 5182 (part 10) RA2019

[#] Specified under National Ambient Air Quality Standards by CPCB.
[*] 24 hourly monitoring values; [**] 1 hourly monitoring values.

Conformity Statement: The monitoring undertaken indicates that Ambient Air Quality Values for monitored parameters are within the levels stipulated under National Ambient Air Quality Standards (NAAQS) 2009.

Note:

1. The test report shall not be reproduced except in full, without written approval of laboratory.
2. Results relate only to the items tested.
3. Any query related to this report will be entertained within 15 days of the report issue date only.
4. Decision Rule is applied.



Himani P. Jozhi
(Authorized Signatory - Pollution & Environment)
-End of Test Report-

We Are Listening & Want to Improve - Complated Register is Available with us Page 1 of 1
Reg. Office: 107, Hiven Light Industrial Estate, Mogli Lane, Malvi, Mumbai - 400016 Tel: 222 42127500 E-mail: contact@aespl.co.in



Environment Compliance Report

GENERAL CONDITIONS

Point 40:- Under the provisions of Environment (Protection) Act, 1986. legal action shall be initiated against the project proponent if it was found that construction of the project has been started without obtaining environmental clearance

Noted

Environment Compliance Report

GENERAL CONDITIONS

Point 41:- Six monthly monitoring reports should be submitted to the Regional office MOEF, Bhopal with copy to this department and MPCB.



CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED
(CIN - U99999 MH 1970 SGC - 014574)

REGD. OFFICE:
"NIRMAL", 2nd Floor, Nariman Point,
Mumbai - 400 021.
PHONE : 00-91-22-6650 0900
FAX : 00-91-22-2202 2509

HEAD OFFICE:
CIDCO Bhavan, CBD Belapur,
Navi Mumbai - 400 614.
PHONE: 00-91-22-6791 8100
FAX : 00-91-22-6791 8166

Ref. No. CIDCO/CE(NMIA)/2022/ 1749

Date : 15.12.2022.

To,
Regional Officer,
Maharashtra Pollution Control Board,
Jog Center, 3rd floor, Mumbai Pune Road,
Wakdevadi, Pune, Maharashtra 411003

**Subject: Submission of Six Monthly compliance status report
up to 31st May 2022**

Ref: -Grant of Environmental Clearance from SEIAA, vide letter no.
SIA/MH/MIS/53158/2019 dated 27.10.2020 for Pradhan Mantri Awas
Yojana (PMAY) Housing scheme at Plot no. 03, Sec-16A, Kharkopar
Railway station (East), Ulwe node, Navi Mumbai, Taluka Panvel, District-
Raigad.

Respected Sir/ Madam,

We are hereby enclosing six monthly compliance status report for the month of 31st
May 2022 as per General Condition in the issued Environmental Clearance.

This is for your kind information and records.

Thanking You,

Yours faithfully,



(R.B. Dhayatkar)
Chief Engineer (NMIA)
CIDCO LTD., 3rd Floor,
CIDCO Bhavan, CBO Belapur,
Navi Mumbai-400614

Environment Compliance Report

GENERAL CONDITIONS

Point 42:- Project proponent shall ensure completion of STP, MSW disposal facility, green belt development prior to occupation of the buildings. As agreed during the SEIAA meeting, PP to explore possibility of utilizing excess treated water in the adjacent area for gardening before discharging it into sewer line No physical occupation or allotment will be given unless all above said environmental infrastructure is installed and made functional including water requirement in Para 2. Prior certification from appropriate authority shall be obtained.

Noted

Environment Compliance Report


GENERAL CONDITIONS

Point 43:- Wet garbage should be treated by Organic Waste Converter and treated waste (manure) should be utilized in the existing premises for gardening. And no wet garbage will be disposed outside the premises. Local authority should ensure this.



OWC Technology report attached

MNC Process





Environment Compliance Report

GENERAL CONDITIONS




Point 44:- Local body should ensure that no occupation certification is issued prior to operation of STP/MSW site etc. with due permission of MPCB

Noted

Environment Compliance Report

GENERAL CONDITIONS

Point 45:-A complete set of all the documents submitted to Department should be forwarded to the Local authority and MPCB

 महाराष्ट्र शासन CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED <small>(CIN - 099999 MH 1970 SOC - 014574)</small>	 CIDCO WE MAKE CITIES
REGD. OFFICE: "NIRMAL", 2nd Floor, Nariman Point, Mumbai - 400 021. PHONE : 00-91-22-6650 0900 FAX : 00-91-22-2202 2509	HEAD OFFICE: CIDCO Bhavan, CBD Belapur, Navi Mumbai - 400 614. PHONE: 00-91-22-6791 8100 FAX : 00-91-22-6791 8166
Ref. No. CIDCO/CE(NMIA)/2022/ १११३	Date: 15.12.2022.
To, Regional Officer, Maharashtra Pollution Control Board, Raigad Bhavan, 6th Floor, Sector -11, C.B.D Belapur, Navi Mumbai-400 614	
Subject: Submission of Six Monthly compliance status report up to 30th Nov 2022	
Ref: -Grant of Environmental Clearance from SEIAA, vide letter no. SIA/MH/MIS/53158/2019 dated 27.10.2020 for Pradhan Mantri Awas Yojana (PMAY) Housing scheme at Plot no. 03, Sec-16A, Kharkapur Railway station (East), Ulwe node, Navi Mumbai, Taluka Parvel, District- Raigad.	
Respected Sir/ Madam,	
We are hereby enclosing six monthly compliance status report for the month of 30 th Nov 2022 as per General Condition in the issued Environmental Clearance.	
This is for your kind information and records.	
Thanking You,	
Yours faithfully,  (R.B. Dhayatkar) Chief Engineer (NMIA) CIDCO LTD., 3rd Floor, CIDCO Bhavan, CBO Belapur, Navi Mumbai-400614	
<small>In case of any corruption related complaints, please visit : www.cidco.maharashtra.gov.in Click on Dakshata link</small>	

Environment Compliance Report

GENERAL CONDITIONS

Point 46:- In the case of any change(s) in the scope of the project, the project would require a fresh appraisal by this Department.

Application for Extension TOR approved

File No.SIA/MH/MIS/71504/2022
Government of India
State Level Environment Impact Assessment Authority
Maharashtra

To,

M/s CIDCO
NMIA Office, 3rd floor, Tower no. 10, Belapur Station complex, CBD Belapur, Navi Mumbai,
Thane-400614
Maharashtra

Tel.No.22-87918100; Email: pmay.cidco@gmail.com

Sub. Terms of Reference to the Pradhan Mantri Awas Yojana (PMAY) Housing Scheme at Plot No. 3, Sector 16, Kharkopar Railway Station (East), Village: Gavhan and Kharkopar, Taluka: Panvel, District: Raigad, State: Maharashtra, India., CIDCO Bhavan, CBD Belapur, Navi Mumbai

Dear Sir/Madam,

This has reference to the proposal submitted in the Ministry of Environment, Forest and Climate Change to prescribe the Terms of Reference (TOR) for undertaking detailed EIA study for the purpose of obtaining Environmental Clearance in accordance with the provisions of the EIA Notification, 2006. For this purpose, the proponent had submitted online information in the prescribed format (Form-1) along with a Pre-feasibility Report. The details of the proposal are given below:

- | | |
|----------------------------------|--|
| 1. Proposal No.: | SIA/MH/MIS/71504/2022 |
| 2. Name of the Proposal: | Pradhan Mantri Awas Yojana (PMAY) Housing Scheme at Plot No. 3, Sector 16, Kharkopar Railway Station (East), Village: Gavhan and Kharkopar, Taluka: Panvel, District: Raigad, State: Maharashtra, India. |
| 3. Category of the Proposal: | INFRA-2 |
| 4. Project/Activity applied for: | 8(b) Townships and Area Development projects. |
| 5. Date of submission for TOR: | 27 Jan 2022 |
| Date : 28-01-2022 | |

Manisha Patankar Mhasikar
(Member secretary (SEIAA))

Office : Room no. 217, second floor, mantralaya Annex, madam cama road, mumbai-32
Phone No : 87918100 Mobile : 9820400948
Email id : psec.env@maharashtra.gov.in

Note : This is auto tor granted letter.

In this regard, under the provisions of the EIA Notification 2000 as amended, the Standard TOR for the purpose of preparing environment impact assessment report and environment management plan for obtaining prior environment clearance is prescribed with public consultation as follows:



Environment Compliance Report

GENERAL CONDITIONS

Point 47:- A separate environment management cell with qualified staff shall be set up for implementation of the stipulated environmental safeguards.

Noted

Environment Compliance Report

GENERAL CONDITIONS

Point 48:- A separate environment management cell with qualified staff shall be set up for implementation of the stipulated environmental safeguards.

Attached Report

8.3.1 Budgetary Allocation for EMP:

Table 8.1 & 8.2 gives the expenditure to be incurred by City and Industrial Development Corporation (CIDCO) on environmental matters during construction and operational phase.

Table 8.1: Expenditure on Environmental Matters during Construction Phase

No.	Component	Description	Basis of costing	Total Cost (Rs. In Lacs)	
1	Air Environment	Cost for Dust suppression	20 nos. of Tankers/ Month x 12 Months x 7 Years x Rs. 600/ Tanker	10.08	
		#Air and Noise quality	By outside MOEF approved Laboratory	--	1.54
		EMP for Batching plant			1.61
2	Water Environment	Drinking water analysis	--	0.21	
3	Land Environment	Site Sanitation	--	10.0	
4	Health & Hygiene	Disinfection- Pest Control at site	10000/ Month x 12 Months x 7 Years	8.40	
		Health-check-up of workers	250 nos. of Workers x Rs. 250/ Worker/	52.50	

Environment Compliance Report

GENERAL CONDITIONS

Point 48:- Conti....

No.	Component	Description	Basis of costing	Total Cost (Rs. In Lacs)
			Month x 12 Months x 7 Years	
Total Cost				84.34

(#Set up cost for onsite sensors including operation and maintenance cost (If provided as suggested in Chapter 4, Section 4.1.3): At actual

Table 8.2: Expenditure on Environmental Matters during Operation Phase

No.	Component	Description	Capital cost Rs. In lacs.	Operational and Maintenance cost (Rs. in lacs/yr)
1	AIR & NOISE ENVIRONMENT			
1.1	Cost for Ambient Air quality & Noise Monitoring	By outside MoEF & CC Approved Laboratory	*No set up cost is involved	0.22
1.2	Cost for DG Stack Exhaust Monitoring	4 nos. of stacks	*No set up cost is involved	0.19
1.3	Cost for Plantation	7671.98 Sq.mt. of Recreational Open Space	42.20	1.20
2	WATER ENVIRONMENT			
2.1	Cost for Water Conservation (Rain Water Harvesting System)	Cost for RWH tanks	55.00	2.75
		Cost for treatment unit for Rain Water collected in tanks	9.00	0.03
		Cost for Rainwater Monitoring	*No set up cost is involved	0.14
3	LAND ENVIRONMENT			
3.1	Cost for Solid Waste Management	Cost for Treatment of biodegradable garbage in OWC	27.00	7.37
		Cost for monitoring of OWC manure	*No set up cost is involved	0.24
4	ENERGY CONSERVATION			
4.1	Use of renewable energy	Cost for Solar PV System	182.00	4.50
Total Cost			315.20	16.64

*No set up cost is involved as monitoring contract shall be given to outside MoEF approved laboratory

(#Additional Operation and maintenance cost for onsite sensors (If provided as suggested in Chapter 4, Section 4.1.3): Rs. 50,000/Annum.

Environment Compliance Report

GENERAL CONDITIONS

Point 49:- The project management shall advertise at least in two local newspapers widely circulated in the region around the project, one of which shall be in the Marathi language of the local concerned within seven days of issue of this letter, informing that the project has been accorded environmental clearance and copies of clearance letter are available with the Maharashtra Pollution Control Board and may also be seen at Website at <http://parivesh.nic.in>

MUMBAI
TUESDAY
MAY 24, 2022

Hindustan Times



PUBLIC NOTICE
CIDCO PMAY Housing
ENVIRONMENTAL CLEARANCE

The State Environmental Impact Assessment Authority (SEIAA), Maharashtra has accorded Environmental Clearance (EC) for CIDCO's Residential cum Commercial housing complex under PMAY Scheme, Package-IV (out of Package-I to IV vide (i) No. SIA/MH/MIS/50802/2019 dated 31/03/2020 for proposed Pradhan Mantri Awas Yojana (PMAY) housing scheme at Plot No. 2, Sector-6 near Bamandongri Railway Station, Ulwe Node, Navi Mumbai, Taluka-Panvel, District-Raigad. (ii) No. SIA/MH/MIS/53158/2019 dated 27/10/2020 for proposed Pradhan Mantri Awas Yojana (PMAY) housing scheme at Plot No. 03, Sector 16A near Kharkopar Railway Station (East), Ulwe Node, Navi Mumbai, Taluka-Panvel, District-Raigad & (iii) No. SIA/MH/MIS/53197/2020 dated 27/10/2020 for proposed Pradhan Mantri Awas Yojana (PMAY) housing scheme at Plot No. 01, Sector 39 at Taloja, Navi Mumbai.

The copies of environmental Clearance are available for reference with Maharashtra State Pollution Control Board and may also be seen at Website at <http://parivesh.nic.in>


The State Environmental Impact Assessment Authority (SEIAA) has accorded the environmental clearance for the said project under the provisions of EIA Notification, 2006.

CIN - U99999 MH 1970 SGC-014574
www.cidco.maharashtra.gov.in

Chief Engineer (NMIA)
CIDCO/PR/085/2022-23

मंगळवार,
दि. २४ मे २०२२

सामना



सार्वजनिक सूचना
सिडको प्रधानमंत्री आवास योजना
पर्यावरण मंजूरी

राज्य पर्यावरण प्रभाव मूल्यांकन प्राधिकरण (SEIAA), महाराष्ट्र यांनी प्रधानमंत्री आवास योजनेतर्गत सिडकोच्या निवासी तथा व्यावसायिक गृहनिर्माण प्रकल्पांतर्गत पॅकेज-४ ला (पॅकेज १ ते ४ पैकी) पर्यावरण मंजूरी (१) No. SIA/MH/MIS/५०८०२/२०१९ दिनांक ३१.०३.२०२० अन्वये, प्लॉट नं. २, सेक्टर ६, बामणडोंगरी रेल्वे स्थानकाजवळ, उलवे नोड, नवी मुंबई, तालुका-पनवेल, जिल्हा-रायगड यांना (२) No. SIA/MH/MIS/५३१५८/२०१९ दिनांक २७.१०.२०२० अन्वये, प्लॉट क्र. ३, सेक्टर १६A खारकोपर रेल्वे स्थानक (पूर्व), उलवे नोड, नवी मुंबई, तालुका-पनवेल, जिल्हा-रायगड यांना व (३) No. SIA/MH/MIS/५३१९७/२०२० दिनांक २७.१०.२०२० अन्वये, प्लॉट क्र. १, सेक्टर ३९, तळोजा, नवी मुंबई यांना पर्यावरणाच्या दृष्टीकोनातून मंजूरी दिली आहे.

सदर मंजूरीच्या प्रती महाराष्ट्र प्रदूषण नियंत्रण महामंडळ यांच्याकडे उपलब्ध आहेत व त्या <http://parivesh.nic.in> या वेबसाईट वर देखील पाहता येईल.

राज्य पर्यावरण प्रभाव मूल्यमापन प्राधिकरण (SEIAA) ने EIA अधिसूचना, २००६ च्या तरतुदीनुसार उक्त प्रकल्पासाठी पर्यावरण मंजूरीला मान्यता दिली आहे.

CIN - U99999 MH 1970 SGC-014574
www.cidco.maharashtra.gov.in

मुख्य अभियंता (न.मुं.आं.वि.)
सिडको/जनसंपर्क/०८५/२०२२-२३

Environment Compliance Report

GENERAL CONDITIONS

Point 50:- Project management should submit half yearly compliance reports in respect of the stipulated prior environment clearance terms and conditions in hard & soft copies to the MPCB & this department, on 1st June & 1st December of each calendar year.



महाराष्ट्र शासन



CIDCO
WE MAKE CITIES

CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED
(CIN - 099999 MH 1970 SOC - 014574)

<p>REGD. OFFICE: "TRIBHAI", 2nd Floor, Nariman Point, Mumbai - 400 021. PHONE: 00-91-22-6600 0900 FAX: 00-91-22-2202 2509 CIDCO/CE(NMIA)/2022/ 1775</p>	<p>HEAD OFFICE: CIDCO Bhavan, CBO Belapur, Navi Mumbai - 400 614. PHONE: 00-91-22-6791 8100 FAX: 00-91-22-6791 8166 15.12.2022.</p>
--	--

Ref. No. To,
Regional Officer,
Maharashtra Pollution Control Board,
Jog Center, 3rd floor, Mumbai Pune Road,
Wakdevadi, Pune, Maharashtra 411003

Date :

**Subject: Submission of Six Monthly compliance status report
up to 30th Nov 2022**

Ref: -Grant of Environmental Clearance from SEIAA, vide letter no. SIA/MH/MIS/53158/2019 dated 27.10.2020 for Pradhan Mantri Awas Yojana (PMAY) Housing scheme at Plot no. 03, Sec-16A, Kharkogar Railway station (East), Ulwe node, Navi Mumbai, Taluka Panvel, District- Raigad.

Respected Sir/ Madam,

We are hereby enclosing six monthly compliance status report for the month of 30th Nov 2022 as per General Condition in the issued Environmental Clearance.

This is for your kind information and records.

Thanking You,

Yours faithfully,

(R.B. Dhayatkar)
Chief Engineer (NMIA)
CIDCO LTD., 3rd Floor,
CIDCO Bhavan, CBO Belapur,
Navi Mumbai-400614



Environment Compliance Report

GENERAL CONDITIONS

Point 51:- A copy of the clearance letter shall be sent by proponent to the concerned Municipal Corporation and the local NGO, if any, from whom suggestions/representations, if any, were received while processing the proposal. The clearance letter shall also be put on the website of the Company by the proponent.

Not Applicable

Environment Compliance Report

GENERAL CONDITIONS

Point 52:- The proponent shall upload the status of compliance of the stipulated EC conditions, including results of monitored data on their website and shall update the same periodically. It shall simultaneously be sent to the Regional Office of MOEF, the respective Zonal Office of CPCB and the SPCB. The criteria pollutant levels namely, SPM, RSPM, SO₂, NO_x (ambient levels as well as stack emissions) or critical sector parameters, indicated for the project shall be monitored and displayed at a convenient location near the main gate of the company in the public domain.


Sr. No.		Parameter	Result	Limits #	Unit	Method of analysis
1.		SO ₂	23.1	80	µg/m ³	IS 5182 (Part 2) RA2017
2.		NO _x	28.8	80	µg/m ³	IS 5182 (Part 6) RA2017
3.		PM ₁₀	69.5	100	µg/m ³	IS 5182 (Part 23) RA2017
4.		CO	0.75	04 *	mg/m ³	IS 5182 (part 10) RA2019

[*] Specified under National Ambient Air Quality Standards by CPCB.
[**] 24 hourly monitoring values; [***] 1 hourly monitoring values.

Conformity Statement: The monitoring undertaken indicates that Ambient Air Quality Values for monitored parameters are within the levels stipulated under National Ambient Air Quality Standards (NAAQS) 2009.

Notes:

- The test report shall not be reproduced except in full, without written approval of laboratory.
- Results relate only to the items tested.
- Any query related to this report will be entertained within 15 days of the report issue date only.
- Decision Rule is applied.





Himani P. Jozhi
(Authorized Signatory - Pollution & Environment)
-End of Test Report-

We Are Listening & Want to Improve - Complaint Register is Available with us
Reg. Office: 107, Hives Light Industrial Estate, Mopli Lane, Mahim, Mumbai - 400016 Tel: 022 42227500 E-mail: complaint@cidco.in Page 1 of 1

Environment Compliance Report

GENERAL CONDITIONS

Point 53:- The project proponent shall also submit six monthly reports on the status of compliance of the stipulated EC conditions including results of monitored data (both in hard copies as well as by e-mail) to the respective Regional Office of MOEF, the respective Zonal Office of CPCB and the SPCB.


 महाराष्ट्र शासन	 WE MAKE CITIES
CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED <small>(CIN - 099999 MH 1970 SGC - 014574)</small>	
REGD. OFFICE: "NIRMAL", 2nd Floor, Nariman Point, Mumbai - 400 021. PHONE : 00-91-22-6650 0900 FAX : 00-91-22-2202 2509	HEAD OFFICE: CIDCO Bhavan, CBO Belapur, Navi Mumbai - 400 614. PHONE: 00-91-22-6791 8100 FAX : 00-91-22-6791 8166
CIDCO/CE(NMIA)/2022/ 1778	15.12.2022.
Ref. No.	Date :
To,	
The Member Secretary, State Level Environmental Impact Assessment Authority (SEIAA) Environment Department Room No. 217, 2nd Floor, Mantralaya, Mumbai -400 032	
Subject: Submission of Six-Monthly compliance status report up to 30th Nov 2022	
Ref: -Grant of Environmental Clearance from SEIAA, vide letter no. SIA/MH/MIS/53158/2019 dated 27.10.2020 for Pradhan Mantri Awas Yojana (PMAY) Housing scheme at Plot no. 03, Sec-16A, Kharkopar Railway station (East), Ulwe node, Navi Mumbai, Taluka Panvel, District- Raigad.	
Respected Sir/ Madam,	
We are hereby enclosing six monthly compliance status report for the month of 30 th Nov 2022 as per General Condition in the issued Environmental Clearance.	
This is for your kind information and records.	
Thanking You,	
Yours faithfully,  (R.B. Dhaytkar) Chief Engineer (NMIA) CIDCO LTD., 3rd Floor, CIDCO Bhavan, CBO Belapur, Navi Mumbai-400614	
<small>In case of any corruption related complaints, please visit : www.cidco.maharashtra.gov.in Click on Dakshata link</small>	

Environment Compliance Report

GENERAL CONDITIONS

Point 54:- The environmental statement for each financial year ending 31st March in Form-V as is mandated to be submitted by the project proponent to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently, shall also be put on the website of the company along with the status of compliance of EC conditions and shall also be sent to the respective Regional Offices of MOEF by e-mail.

8/20/22, 11:55 AM MPCB Web Portal



महाराष्ट्र प्रदूषण नियंत्रण मंडळ

Industries
Applications | Dashboard | Change Password | Industry Documents | Logout

FORM V
Sl.No. Rule 14
Environmental Audit Report for the financial Year ending the 31st March 2022

Part A

Company Information

* Company Name M/s. City and Industrial Development Corporatio	* Application UAN number MPCB-CONSENT-000093638	* Financial Year April 2021 - March 2022
* Address CIDCO Bhavan, CBD Belapur, Navi Mumbai		
* Plot Number Plot No. 3, Sector 16A	* Taluka Panvel	* Village Navi Mumbai
* Capital Investment (in lakhs) 38283.00	* Scale L,SI	
* City Raigad	* Pincode 410206	
* Person Name Mr. Rajendra Deyarkar	* Designation CHIEF ENGINEER	
* Telephone Number 9987567207	* Fax Number	* Email gpkate12@gmail.com
* Region SRO - Raigad I	* Industry Category Orange	* Industry Type O21 Building and construction project more t
* Last Environmental statement submitted online <input type="radio"/> No <input type="radio"/> Yes	* Consent Number MPCB-CONSENT-000093638	* Consent Issue Date 2020-11-12
* Consent Valid Upto 2025-11-11	* Establishment Year 2020	* Date of last environment statement submitted

Product Information

* Product Name	* Consent Quantity	* Actual Quantity	* UOM
NA	0	0	Ton/Y

Add More

By-product Information

* By Product Name	* Consent Quantity	* Actual Quantity	* UOM
NA	0	0	Ton/Y

Add More

Part B
1) Water Consumption in m3/day

Environment Compliance Report

GENERAL CONDITIONS

Point 55:- The environmental clearance is being issued without prejudice to the action initiated under EP Act or any court case pending in the court of law and it does not mean that project proponent has not violated any environmental laws in the past and whatever decision under EP Act or of the Hon'ble court will be binding on the project proponent. Hence this clearance does not give immunity to the project proponent in the case filed against him, if any or action initiated under EP Act.

Noted



Environment Compliance Report

GENERAL CONDITIONS

Point 56:- In case of submission of false document and non-compliance of stipulated conditions, Authority/ Environment Department will revoke or suspend the Environment clearance without any intimation and initiate appropriate legal action under Environmental Protection Act, 1986

For Info



Environment Compliance Report

GENERAL CONDITIONS

Point 57:- The Environment department reserves the right to add any stringent condition or to revoke the clearance if conditions stipulated are not implemented to the satisfaction of the department or for that matter, for any other administrative reason

For Info



Environment Compliance Report

GENERAL CONDITIONS

Point 58:- Validity of Environment Clearance: The environmental clearance accorded shall be valid as per EIA Notification, 2006, amended time to time.

For Info

Environment Compliance Report

GENERAL CONDITIONS

Point 59:- In case of any deviation or alteration in the project proposed from those submitted to this department for clearance, a fresh reference should be made to the department to assess the adequacy of the condition(s) imposed and to incorporate additional environmental protection measures required, if any.

Application for Extension TOR approved

File No.SIA/MH/MIS/71504/2022
Government of India
State Level Environment Impact Assessment Authority
Maharashtra

To,

M/s CIDCO
NMIA Office, 3rd floor, Tower no. 10, Belapur Station complex, CBD Belapur, Navi Mumbai,
Thane-400614
Maharashtra

Tel.No.22-87918100; Email:pmay.cidco@gmail.com

Sub. Terms of Reference to the Pradhan Mantri Awas Yojana (PMAY) Housing Scheme at Plot No. 3, Sector 16, Kharkopar Railway Station (East), Village: Gavhan and Kharkopar, Taluka: Panvel, District: Raigad, State: Maharashtra, India., CIDCO Bhavan, CBD Belapur, Navi Mumbai

Dear Sir/Madam,

This has reference to the proposal submitted in the Ministry of Environment, Forest and Climate Change to prescribe the Terms of Reference (TOR) for undertaking detailed EIA study for the purpose of obtaining Environmental Clearance in accordance with the provisions of the EIA Notification, 2006. For this purpose, the proponent had submitted online information in the prescribed format (Form-1) along with a Pre-feasibility Report. The details of the proposal are given below:

- | | |
|----------------------------------|--|
| 1. Proposal No.: | SIA/MH/MIS/71504/2022 |
| 2. Name of the Proposal: | Pradhan Mantri Awas Yojana (PMAY) Housing Scheme at Plot No. 3, Sector 10, Kharkopar Railway Station (East), Village: Gavhan and Kharkopar, Taluka: Panvel, District: Raigad, State: Maharashtra, India. |
| 3. Category of the Proposal: | INFRA-2 |
| 4. Project/Activity applied for: | 8(b) Townships and Area Development projects. |
| 5. Date of submission for TOR: | 27 Jan 2022 |

Date : 28-01-2022

Manisha Patankar Mhasikar
(Member secretary (SEIAA))

Office : Room no. 217, second floor, mantralaya Annex, madam cama road, mumbai-32
Phone No : 87918100 Mobile : 9820400948
Email id : psec.env@maharashtra.gov.in

Note : This is auto tor granted letter.

In this regard, under the provisions of the EIA Notification 2000 as amended, the Standard TOR for the purpose of preparing environment impact assessment report and environment management plan for obtaining prior environment clearance is prescribed with public consultation as follows:



Environment Compliance Report

GENERAL CONDITIONS

Point 60:- The above stipulations would be enforced among others under the Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986 and rules there under, Hazardous Wastes (Management and Handling) Rules, 1989 and its amendments, the public Liability Insurance Act, 1991 and its amendments.

For info

Environment Compliance Report

GENERAL CONDITIONS

Point 61:- Any appeal against this Environment clearance shall lie with the National Green Tribunal (Western Zone Bench, Pune), New Administrative Building, 1st Floor, D - Wing, Opposite Council Hall, Pune, if preferred, within 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.

For info



Environment Compliance Report

Thank You